


 महाराष्ट्र शासन	मुख्य अणुजीव शास्त्रज्ञ जिल्हा सार्वजनिक आरोग्य प्रयोगशाळा, ठाणे प्रादेशिक मनोरुग्णालय, ठाणे आवाराच्या बाजूला, जिल्हा परिषद प्रशिक्षण केंद्रा जवळ, ठाणे (प) - ४०० ६०४ दूरध्वनी - कार्यालय :- (०२२) २५८२७७५४ Email : cbthane01@gmail.com					
आरोग्यसेवा	जा. क्र. जि.आप्रशा / अणुजीव अहवाल / 2175 / 2026 दि. 25/06/2026					
REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER						
✓ Name & Address of Sender	St. Anthony Convent Higher Secondary School Nt. Xavier's Church, Rameshwadi Badlapur (W) 421503					
Sender's Letter No. & Date	../11.06.2026					
Laboratory Reference No.	5023					
Date of Collection	11.06.2026					
Date of Arrival at Laboratory	11.06.2026					
Date of Commencing Examination	11.06.2026					
Sr. No.	Particular of Samples	Result of Analysis Most Probable Number Per 100 ml. <table border="1"> <tr> <th>Coliforms</th> <th>Thermotolerant Coliforms</th> <th>E.Coli</th> <th>Remarks</th> </tr> </table>	Coliforms	Thermotolerant Coliforms	E.Coli	Remarks
Coliforms	Thermotolerant Coliforms	E.Coli	Remarks			
१	नळाचे पाणी	<table border="1"> <tr> <td align="center">0</td> <td align="center">-</td> <td align="center">-</td> <td align="center">पिण्यास योग्य</td> </tr> </table>	0	-	-	पिण्यास योग्य
0	-	-	पिण्यास योग्य			
अभिप्राय-पिण्यास अयोग्य पाण्यावर प्रमाणित क्लोरिनच्या मात्रेसह योग्य ती प्रक्रिया करून व सुक्ष्मजीवीय पुनर्तपासणीनंतर पिण्यास योग्य असल्याची खात्री झाल्यानंतरच ते पाणी पिण्यासाठी वापरता येईल.						
Note :- 1. Above water sample/s was/were not collected by this laboratory. 2. This report is restricted only for the samples submitted to this laboratory						


 मुख्य अणुजीव शास्त्रज्ञ
 जिल्हा सार्वजनिक आरोग्य प्रयोगशाळा,
 ठाणे

District Public Health Laboratory, Thane

E-mail-ID : cbthane01@gmail.com

Phone No. : 25827754

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection : - —

Date of Receipt :- 16.6.2026

Date of Examination :- 16.6.2026
on words.

Lab. Ref. No. - TPW-32 (All the Analytical Results are in mg./Litre except pH. Turbidity)

Sr. No.	TEST PARAMETER	(1)	(2)	(3)	BIS Specification 10500 : 2015 Normal Values	
		Tap Water	—	—	Desirable Limits	Permissible Limits
1.	Physical Appearance	Clear	—	—	---	---
2.	Odour	Odourless	—	—	Agreeable	Agreeable
3.	Turbidity (as N.T.U.)	<1.0	—	—	1.0	5.0
4.	pH Value	7.58	—	—	6.5 to 8.5	No Relaxation
5.	Chlorides (as Cl)	20.20	—	—	250	1000
6.	Nitrates (as No3)	0.917	—	—	45	No Relaxation
7.	Total Hardness (as CaCO3)	74.16	—	—	200	600
8.	Alkalinity (as CaCO3)	68.31	—	—	200	600
9.	Total Dissolved Solids	140.43	—	—	500	2000
10.	Iron (as Fe)	Not Detected	—	—	1.0	No Relaxation
11.	Fluoride (as F)	0.204	—	—	1.0	1.5
12.	Other Tests (if any)	—	—	—		
13.						
14.						
15.						
16.						
17.						
18.						
19.						
20.						

- This report is restricted only for the Sample/s Submitted to this Laboratory.
- This Sample/s is / are not Collected by this Laboratory.

[P.T.O.]

REMARKS

A) Sample No. (8) 1 is/are potable/chemically fit for drinking purpose on the basis of analysed parameters only. as per BIS specification 10500:2015

However, this / these water source's can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

B) Sample No. (s) _____ Contains _____

However, if there is no any other alternate source available nearby then this/these water Source's can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

C) Sample No. (s) _____ Contains _____

Hence, this/these water Source's is/are chemically non-potable/unfit for drinking purpose on the basis of analysed parameters only.

HEALTH SERVICES

No. 2179

Date : 25.06.2026.

Forwarded with compliment to : Principal,

St. Anthony's Convent Higher Secondary School,
Besides St. Francis Xavier's Church, Church Road,
Badlapur (W)

With reference to letter No. : 2026-27/pri-57 Dated : 16.6.2026.

Fees Rs. : 1200/-

Receipt No. and Date : 6759183
16.6.2026.

[Signature]
Chief Bacteriologist
District Public Health Laboratory, Thane

The contents hereof have been translated from the Marathi language into the English language.

On the letter head of OFFICE OF THE CHIEF BACTERIOLOGIST


DISTRICT PUBLIC HEALTH LABORATORY, THANE

Regional Mental Hospital Campus, Thane Bazar Road, Near Zilla Parishad Training Centre, Thane (West)
- 400604. Telephone (Office): (022) 25827754. E-mail: cbthane01@gmail.com

Public Health Department
Government of Maharashtra

Outward No.: 2175/2026

Date: 25/06/2026



REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER

Address of Sender		St. Anthony Convent Higher Secondary School Nt. Xavier's Church, Rameshwadi Badlapur (W) 421503			
Sender's Letter No. & Date		../11.06.2026			
Laboratory Reference No.		5023			
Date of Collection		11.06.2026			
Date of Arrival at Laboratory		11.06.2026			
Date of Commencing Examination		11.06.2026			
Sr. No.	Particular of Samples	Result of Analysis Most Probable Number Per 100 ml.			
		Coliforms	Thermotolerant Coliforms	E.Coli	Remarks
1	Tap Water	0	-	-	Fit for Drinking

Opinion

The submitted tap water sample was examined bacteriologically. No coliform organisms were detected in 100 ml of the sample. Therefore, the sample is found fit for drinking purpose.

However, water intended for drinking should be regularly monitored and, wherever necessary, subjected to proper treatment and disinfection to ensure continued bacteriological safety.

Notes

1. The water sample was not collected by this laboratory.
2. This report is restricted only to the sample submitted to this laboratory.

Translated by me:



Rubber stamp of Chief Bacteriologist
District Public Health Laboratory, Thane

ATTESTED BY ME

PRATIKSHA M. KAMBLE
Advocate & Notary
GOVT. OF INDIA
Regd. No. 55351
B 106, Shreeji Garden Society,
Nr Valivali Gaon, Murbad Barvi,
Dam Road Badlapur, Thane,
Maharashtra

04 SEP 2026

REMARKS

A) Sample No. (s) 1 is/are potable/chemically fit for drinking purpose on the basis of analysed parameters only. as per BIS specification 10500:2015

However, this / these water source's can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

B) Sample No. (s) _____ Contains _____

However, if there is no any other alternate source available nearby then this/these water Source's can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

C) Sample No. (s) _____ Contains _____

Hence, this/these water Source's is/are chemically non-potable/unfit for drinking purpose on the basis of analysed parameters only.

HEALTH SERVICES

No. 2179

Date : 25.06.2026.

Forwarded with compliment to : Principal,
St. Anthony's Convent Higher Secondary School,
Besides St. Francis Xavier's Church, Church Road,
Badlapur (W)

With reference to letter No. : 2026-27/pri-57 Dated : 16.6.2026.


Fees Rs. : 1200/-Receipt No. and Date : 675918316.6.2026

[Signature]
Chief Bacteriologist

District Public Health Laboratory, Thane

District Public Health Laboratory, Thane

E-mail-ID : cbthane01@gmail.com



Phone No. 25827754

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection : - —

Date of Receipt :- 16.6.2026

Date of Examination :- 16.6.2026

Ref. No. - TPW-32 (All the Analytical Results are in mg./Litre except pH, Turbidity)

on words.

Sr. No.	TEST PARAMETER	(1)	(2)	(3)	BIS Specification 10500 : 2015 Normal Values	
		Tap Water	—	—	Desirable Limits	Permissible Limits
	Physical Appearance	Clear	—	—	---	---
	Odour	Odourless	—	—	Agreeable	Agreeable
	Turbidity (as N.T.U.)	<1.0	—	—	1.0	5.0
4.	pH Value	7.58	—	—	6.5 to 8.5	No Relaxation
5.	Chlorides (as Cl)	20.20	—	—	250	1000
6.	Nitrates (as No3)	0.917	—	—	45	No Relaxation
7.	Total Hardness (as CaCO3)	74.16	—	—	200	600
8.	Alkalinity (as CaCO3)	68.31	—	—	200	600
9.	Total Dissolved Solids	140.43	—	—	500	2000
10.	Iron (as Fe)	Not Detected	—	—	1.0	No Relaxation
11.	Fluoride (as F)	0.204	—	—	1.0	1.5
12.	Other Tests (if any)	—	—	—		
13.						
14.						
15.						
16.						
17.						
18.						
19.						
20.						

- This report is restricted only for the Sample/ Submitted to this Laboratory.
- This Sample/ is / are not Collected by this Laboratory.



[P.T.O.]